

REGISTER YOUR Bio-Shield UV-C Air Sanitizer

Receive reminders to order a replacement Lamp every year.

Register to enable us to provide the best service possible in keeping your UV-C Air Sanitizer unit performing at its best.

REGISTRATION INFORMATION

Date of Purchase _____ Purchased From _____
NAME: _____
TEL: (____) _____
ADDRESS: _____
CITY: _____ **STATE:** _____ **ZIP CODE:** _____
EMAIL: _____
Provide Email to receive an annual reminder to replace your Lamp.

The UV-C Lamp should be replaced once a year.

Lamp part numbers: J-TUV20WTS 4P.SE (Standard 17" Lamp)
J-TUV16WTS 4P.SE (12" Lamp)

To Register: Mail back this form, Fax this form to
(714) 993-2126, go to www.UVCairSanitizer.com, or Email
this form to ConsumerService@Joneca.com

Joneca Corporation
4332 E. La Palma Ave.
Anaheim, CA. 92807

EQUIPMENT WARRANTY

Joneca Corporation warrants to the original buyer that its Products shall be free from defects in material or workmanship under normal use and service for the periods of time set forth below. This warranty is contingent upon proper use of Products and will not apply if adjustment, repair or parts replacement is required because of an accident, unusual physical, electrical or electro-mechanical stress, neglect, misuse, failure of electric power, humidity control, transportation, unauthorized repair actions, or not installed or maintained in accordance with Joneca Corporation's specifications hereunder, or where Product serial numbers have been altered, defaced, or removed. Joneca Corporation's obligation under this warranty shall not arise until the Purchaser of the Product returns the defective part to Joneca Corporation or their authorized retailer or distributor. This warranty is limited to the repair and/or replacement of parts. This warranty does not cover any labor or subsequent damage incurred as the result of Product failure or indirectly arising from the design, construction, installation, servicing, or operation of Products. Joneca Corporation's and its resellers' liability under this warranty shall in no event exceed the cost of goods sold under the original sale contract.

Under the conditions specified above, Joneca Corporation warrants all Product fixtures for a period of two (2) year from date of purchase and all lamps for a period of 12 months from date of installation provided lamps are installed within 3 months from date of purchase. Buyer must provide proof of purchase. This is Joneca Corporation's sole warranty. No warranties are extended beyond those described herein and it is expressly agreed that this warranty will be in lieu of all warranties of fitness and merchantability. Joneca Corporation neither assumes, nor authorizes any person to assume for it, any obligation in connection with the Products. Buyer shall not return to Joneca Corporation any allegedly defective goods without Joneca Corporation's prior written authorization. This warranty may not be assigned or transferred.

Joneca Corporation
4332 E. La Palma Ave.
Anaheim, CA. 92807

CUSTOMER SERVICE: 888-8JONECA (1-888-856-6322) FAX: 714-993-2126
www.Joneca.com

Specifications subject to change without notice. © Joneca Corporation 2014, All Rights Reserved

IM-UVC-141



BIO-SHIELD UV-C
AIR SANITIZER SYSTEM
Cleans, Sanitizes, and Freshens Air in Your Entire Home!

GENERAL INSTALLATION INSTRUCTIONS

CAUTION! Never Expose Eyes or Skin directly to UV-C

Read all Materials before Starting.

APPLICATION:



The Bio-Shield UV-C Air Sanitizer™ delivers 20 watts of sanitizing UV-C power to heating and air conditioning units that are circulating air throughout the home. Its lamp and socket are water-resistant, and because it is powered by a 24V converter without danger of shock, fire or code issues becomes quite simple. It also makes for a safe and affordable installation that meets most electrical codes. The Bio-Shield Air Sanitizer™ installs from the exterior of HVAC equipment. Simply create a 2 7/8" insertion hole (with the hole saw provided) at the intended site, mount the fixture and plug it to a suitable 110-120 volt wall outlet. **Fixture is meant to operate continuously (24/7/365) to avoid growth of mold and bacteria, etc. under optimum conditions even when A/C-Heating unit itself is off.**

SAFETY CONSIDERATIONS

Improper installation, adjustment, alteration, service, maintenance, or use can cause fire, electrical shock, or other conditions which may cause personal injury or property damage. If you have questions or difficulty in installation please consult with Joneca Corporation for information or assistance. Follow all safety codes, wear safety glasses and work gloves. Read all instructions thoroughly.

Understand the signal words DANGER, WARNING or CAUTION. These words are universally used for overall safety. DANGER identifies the most serious hazards, which will result in severe personal injury or death. WARNING signifies hazards, which could result in personal injury or death. CAUTION is used to identify unsafe practices, which would result in minor personal injury or product and property damage.

WARNING: Before installing or servicing this unit, turn off all power to both the heating/air conditioning unit and the wall outlet into which the Bio-Shield Air Sanitizer™ will be plugged. There may be more than one (1) switch.

General:


- 1 Bio-Shield Air Sanitizer™ Fixtures can be used to bathe surfaces, the air or both with UV-C energy. The most common area for installation is in the supply duct and mixed air plenums (ductwork) or any combination of locations. If installed on the return side, it should be at least 18" from any filter. For a more Advanced Installation: if it is known **exactly** where the coils, refrigerant line, fan, drain pan and other component are located, and the installation hole can be drilled without affecting any of these or other components, the Bio-Shield Air Sanitizer™ can be installed near any of those components. Joneca Corporation is not responsible for any damage to HVAC if installation is installed in Advanced Installation areas.
- 2 Check first for power availability of an 110V-120V wall socket.


Power Ratings:

The BIO-SHIELD UV-C AIR SANITIZER™ is rated at 24V AC/DC-50/60Hz, 1Amp which is stepped down from the 110V-120V wall outlet by a 24V Adapter.

⚠ Installation (designed for metal ductwork and plenum):

⚠ CAUTION: Plugging the 24V Adapter into an outlet other than 110V-120V volt labeled voltage voids product warranty and may do added damage to the entire system.



1. Once the mounting location is identified, apply the yellow Installation Template sticker to the surface and use template to locate position to cut hole as per Photo A.
2. Using the metal hole saw provided, cut a 2 7/8" lamp hole as per Photo B with drill bit provided.
3. When installing on duct-board (as opposed to metal ductwork), use provided galvanized duct-board Octagon Mounting Plate to provide stronger mounting surface. Position Octagon Mounting Plate with duct-tape, no need to use screws. Apply supplied Installation Template on top of installed duct-board Octagon Mounting Plate. → 
4. Slide Mounting Ring into hole and affix with 3 Phillips screws (provided) as per Photo C.
5. Remove LampClamp™ 'nut' from blue power supply. Insert UV Lamp into socket until it "clicks" in. Slide LampClamp™ over end of UV Lamp and finger tighten.



Installation (continued):

6. Carefully insert fixture with lamp installed into duct thru Mounting Ring as per Photo D.
7. Line up holes of white connector cap to metal pins on Power Supply as per Photo E.
8. Turn clock-wise until Power Supply is fully installed after which the system should appear as in Photo F.
9. Slide yellow Locking Clip to lock Power Supply into Mounting Ring.

⚠ CAUTION: Do not drill into refrigerant line or fan, etc.
CAUTION: After cutting hole avoid sharp edges.

Connecting Power:

1. A 24V AC/DC Adapter is provided with your purchase. Plug adapter into 110V-120V wall socket and secure.



Maintenance

UV-C lamps should be replaced on an annual basis. While there still may be a visible blue light, this is not an indication of UV-C output (the UVC wavelength is invisible). Contact your local Bio-Shield UV-C Air Sanitizer™ distributor or visit www.UvcAirSanitizer.com/
 Lamp part numbers: J-TUV20WT5 4P.SE (Standard 17" Lamp) or J-TUV16WT5 4P.SE (12" Lamp)